

AON SPRINKLER CERTIFICATION



Aon New Zealand

Aon Sprinkler Certification
Aon Building, 1st Floor,
4 Fred Thomas Drive,
Takapuna, North Shore City
Telephone: 09 – 486 9761
Fax: 09 – 486 0112

Aon Sprinkler Certification Technical Note		
Note Number: 11-08	Issue: 1	Date: 4 April 2011
Subject	Fire Fighting Water Supplies NZS4541:2007 clause 604.1.8.2	
Notice: Aon Sprinkler Certification Technical Notes provide guidance notes which may be used in certification of sprinkler installations by Aon New Zealand. If sprinkler installations are being certified by any other Sprinkler System Certifier, these Technical Notes may not apply.		

Please find attached a copy of New Zealand Fire Service's National Notice 22/2011.

This clarifies that any correspondence regarding water supplies not being able to support simultaneous sprinkler and hydrant demands is to be sent to the National Commander, attention Waivers Officer.

The written advice must include an estimate of the shortfall of the water supply. We would recommend that the advice should also include a copy of the block plan for the site.

Chris Mak
Technical Services Manager