

NZS4219 Design Approach

Possible Future Direction for NZS4541?

January 2015

Chris Mak

Background

- NZS4219 :2009
 - Provides seismic design requirements for services in buildings
 - Excludes Sprinkler System Piping
 - When written, NZS4541 had it right
 - Wellington 2013 Earthquake
 - Did the Fire Industry get it right?
 - Anecdotal evidence
 - ♦ Other trades did not!
 - Not withstanding
 - Standard for Sprinkler Systems likely to increase



NZS4541:2013

- Clause 403.12.2

All pipework shall be designed to resist repeated forces due to seismic acceleration of 1.0 g acting on the mass of the pipework in any direction in addition to the gravity force.

NOTE - This load may be greater than the requirements of NZS 1170.5, and may increase the support size but it eliminates the need for a more detailed study.

Aon is aware that some parties consider:

- This clause is an inadvertent error
- This clause is inadequate
- Proposal to amend NZBC
 - Replace 1.0g by the factor C calculated by NZS4219 Equation 3.2

NZS4219 Seismic Design Coefficients

- A guide to its use
- How to find the information you need?

NZS4219 Equation 3.2

$$C = 2.7 C_H Z C_p R_c$$

- $C_H = 3.0$ above ground floor, or 1.0 at or below ground floor
- $Z =$ seismic zone factor (Location based) Slide 5
- $C_p =$ Performance Factor Slide 6
- $R_c =$ Component Performance Factor Slide 7 & 8

Seismic Z Factor

- Refer
 - Informative
 - NZS4541:2013 Appendix Q
 - Normative
 - NZS4219 Table 3 or figure 2

Examples

- Auckland – 0.13
- Rotorua - 0.24
- Wellington – 0.40
- **Arthur’s Pass – 0.60**
- Christchurch – 0.30
- Dunedin – 0.13

NZS 4541:2013

APPENDIX Q – Z VALUES AND SHORTEST MAJOR FAULT DISTANCES D FOR NEW ZEALAND

(Informative)

Q1 REPRODUCED FROM NZS 1170.5 AND VERIFICATION METHOD B1/VM1 OF THE COMPLIANCE DOCUMENTS TO THE NZBC

Users should refer to the current version of NZS 1170.5 for authoritative information.

Table Q1 – Z values and shortest major fault distances D for New Zealand locations (north to south)

#	Location	Z	D (km)*	#	Location	Z	D (km)*
1	Kaitia	0.13	–	39	Gisborne	0.36	–
2	Pahia/Russell	0.13	–	40	Wairoa	0.37	–
3	Kaikōhe	0.13	–	41	Waitara	0.18	–
4	Whangarei	0.13	–	42	New Plymouth	0.18	–
5	Dargaville	0.13	–	43	Inglewood	0.18	–
6	Warkworth	0.13	–	44	Stratford	0.18	–
7	Auckland	0.13	–	45	Opunake	0.18	–
8	Manukau City	0.13	–	46	Hawera	0.18	–
9	Waikū	0.13	–	47	Patea	0.19	–
10	Pukekohe	0.13	–	48	Raetihi	0.26	–
11	Thames	0.16	–	49	Ohakune	0.27	–
12	Paeroa	0.18	–	50	Waiouru	0.29	–
13	Waihi	0.18	–	51	Napier	0.38	–
14	Huntly	0.15	–	52	Hastings	0.39	–
15	Ngāruawāhia	0.15	–	53	Wanganui	0.25	–
16	Morrinsville	0.18	–	54	Waipawa	0.41	–
17	Te Aroha	0.18	–	55	Waipukurau	0.41	–
18	Tauranga	0.20	–	56	Tairāpapa	0.33	–
19	Mount Maunganui	0.20	–	57	Marton	0.30	–
20	Hamilton	0.16	–	58	Bulls	0.31	–
21	Cambridge	0.18	–	59	Feilding	0.37	–
22	Te Awamutu	0.17	–	60	Palmerston North	0.38	8 – 16
23	Matamata	0.19	–	61	Dannevirke	0.42	10
24	Te Puke	0.22	–	62	Woodville	0.41	≤ 2
25	Putaruru	0.21	–	63	Pahiatua	0.42	8
26	Tokoroa	0.21	–	64	Foxton/Foxton Beach	0.36	–
27	Otorohanga	0.17	–	65	Levin	0.40	–
28	Te Kuiti	0.18	–	66	Otaki	0.40	–
29	Mangakino	0.21	–	67	Waikanae	0.40	15 – 20
30	Rotorua	0.24	–	68	Paraparaumu	0.40	14 – 20
31	Kawerau	0.29	–	69	Masterton	0.42	6 – 10
32	Whakatane	0.30	–	70	Porirua	0.40	8 – 12
33	Opoiki	0.30	–	71	Wellington CBD (north of Basin Reserve)	0.40	≤ 2
34	Ruatoria	0.33	–	72	Wellington	0.40	0 – 8
35	Murupara	0.30	–				
36	Taupo	0.28	–				
37	Taumarunui	0.21	–				
38	Turangi	0.27	–				

COPYRIGHT © Standards New Zealand

Q - 1

C_p Performance factor

- Anchors fixings or fasteners
 - $C_p = 0.85$

- Braces and Supports (for category P4 components)
 - $C_p = 0.85$ or from Appendix C

- Appendix C
 - Steel Pipe flanged, welded or grooved
 - $C_p = 0.45$
 - Steel Pipe, screwed joints
 - $C_p = 0.65$

Building Importance Levels

- NZS4219 Appendix A

- IL 1 – Structures with low hazard to life
 - Farm Buildings, towers in rural situations, Buildings less than 30m²
 - *Unlikely* to be sprinklered.

- IL2 - Normal Buildings not IL 1,3 or 4
 - Single family dwellings, car parks
 - Careful review of potential IL3 buildings to see if IL4?

- IL3 - Structures that may contain people in crowds, contents of high value to the community or pose risks to people in crowds
 - More than 300 people in one area, primary schools with a capacity greater than 250, public assembly greater than 1,000m², or commercial buildings with gross area greater than 10,000m²

- IL4 – Structures with special post disaster functions
 - Medical emergency or surgical facilities
 - Police and fire stations
 - Buildings containing hazardous materials capable of causing hazardous conditions past boundary

- IL5 – Special structures posing catastrophic risk to the community
 - Major dams.

R_c Component Risk Factor

- Fire Fighting Systems (other than sprinkler systems) are a Part Category P4
 - Treat Sprinklers as P4

Component Risk Factor for Part Category 4		
Building Importance Factor		
1 & 2	3	4
1.0	1.30	1.80

Example 1 - Single level primary school in Northland - 200 students

$$C = 2.7 C_H Z C_p R_c$$

- Single level building, therefore $C_H = 1.0$
- Northland $Z=0.13$
- Fasteners, $C_p = 0.85$
 - Threaded Pipe, from Appendix C, $C_p = 0.65$.
- IL2 Building, $R_c = 1.0$

- $C = 2.7 \times 1.0 \times 0.13 \times 0.85 \times 1.0$
 $= 0.3g$

Example 2 – Multi-Level Major Hospital in Wellington/Christchurch

$$C = 2.7 C_H Z C_p R_c$$

- Multi level building, therefore $C_H = 3.0$
- Wellington $Z = 0.40$
- Fasteners, $C_p = 0.85$
 - Threaded Pipe, from Appendix C, $C_p = 0.65$
 - Grooved pipe, from Appendix C, $C_p = 0.45$
- IL4 Building, $R_c = 1.8$

- $C = 2.7 \times 3.0 \times 0.40 \times 0.85 \times 1.8$
 $= 4.95 \text{ g}$

King Canute

